

Certificate of Analysis

Product Name : Refrigerant R600A

Sr. No.	Parameters	Unit	Specification	Results	Test Method
1	Appearance	Pass or Fail	Colorless, clarity, liquid gas	Qualified	QPC/STP/R600/01
2	Purity	%($\geq$)	99.60	99.89	AHRI 700-2014(Part 2)
3	Moisture	%($\leq$)	0.0020	0.0013	AHRI 700-2014(Part 9)
4	Acidity (as HCl)	%($\leq$)	0.0001	Undetected	AHRI 700-2014(Part 9)
5	Evaporation Residues	% by weight Max.	0.005	0.001	AHRI 700-2014(Part 4)
6	Air & Other Non-Condensable in Vapour Phase	% by volume Max	1.5	1.43	AHRI 700-2014(Part 3)
7	Odor	Pass or Fail	No Strange Odor	Qualified	QPC/STP/R600/01

Above Specification as Per AHRI 700_2019

Note: 1. This test report shall not be reproduced in half or full without written permission of lab.

This certificate has been generated electronically and is valid without signature.